Government of Andhra Pradesh

A.P. State Disaster Response and Fire Services Department

No Objection Certificate for Occupancy

To

File No: 20236/KRN/RFO/2023

The District Educational Officer,

Date: 09/11/2023

Kurnool

Sir/Madam.

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - No Objection Certificate for Occupancy to the existing / newly constructed Multi Storeyed Building (Delhi Public School run by KJR Educational Society) KJR Educational Society, Sy.No.342, D.No. 1-90-KC1, Chinna Tekur Village, Kallur Mandal, Kurnool District - Regarding.

Ref:

- 1. Online Application Dt. 13-10-2023, KJR Educational Society, Sy.No.342, D.No. 1-90-KC1, Chinna Tekur Village, Kallur Mandal, Kurnool District
- 2. Online Inspection Report submitted by Officers of this Department on 09-11-2023.

-- X --

It is to inform that KJR Educational Society applied for No Objection Certificate on 13-10-2023 for Occupancy to the existing / newly constructed Multi Storeyed Building for Delhi Public School run by KJR Educational Society at Sy.No.342, D.No. 1-90-KC1, Chinna Tekur Village, Kallur Mandal, Kurnool District. The officers of the department have scrutinized the information, documents and plans submitted by the applicant along with the undertaking provided by the applicant, and have submitted the following report.

Delhi Public School

2. The builder has constructed a Non Multi Storeyed Building with Ground Floor + 3 Upper Floors with a height of 14.9 Mtrs for Educational Occupancy (Category - B1) in a total plot area of 28044.71 sq. meters.

3. The builder has provided open spaces all around the building

Side	Open Space Required as per 119 APBR 2016	Open Space Provided by the Builder
North	6 Meters	10.00 Meters
East	3 Meters	10.00 Meters
South	6 Meters	10.00 Meters
West	6 Meters	10.00 Meters

4. The builder has constructed following means of escape:

SI	Details of Staircases	Required Nos / Meters as per A.P.B.R		Provided Nos / Meters
1	Internal Staircases	Min 1 No Meters Each		4 Nos 1.46 Meters Each
2	External Staircases	Min 1 No Meters Each	a distribution	3 Nos 1.48 Meters Each
	Total	2 Nos.	9.00 Meters	10.29 Meters

5. The builder has proposed to provide Occupant Load:

SI	Floor	Built up area (Sq Mtrs)	Occupancy Type	as declared	No of Occupants as per NBC	Aggregate width of Staircases Required (Meters)	Aggregate width of Staircases Provided(Meters)	
1	Ground Floor	4067.25	Educational	1000	1016	10.00	10.30	
2	1st Floor	3784	Educational	945	946	9.45	10.30	
3	2nd Floor	3784	Educational	945	946	9.45	10.30	
4	3rd Floor	3784	Educational	945	946	9.45	10.30	
	Total	15419.25		3835	3854			

6. The minimum Fire Fighting Installations required and provided as per Table 7 of Part 4 of National Building Code of India 2016 are:

SI	Fire Safety System	Minimum Required	Provided
1	Fire Extinguishers	155 Nos.	155 Nos.
2	Hose Reel Systems	17 Nos.	20 Nos.
3	Terrace Tank	10000 Ltrs	50000 Ltrs. Ltrs
4	Booster Pump	450 LPM	05 Nos. 450 LPM
5	Additional Fire Safety measures	NA	

7. The builder has provided the following floorwise Fire Fighting installations as per Table 7 of Part - 4 of NBC of India 2016.

SI.	Floor	Fire Ext.	Hose Reel	Wet Riser	Down Comer	Yard Hydrants	Sprinklers	МСР	Auto. Det.	Underground Tank	Terrace Tank	Fire Pump	Booster
1	Ground Floor	41	5 /5				0 /					- шпр	Tump
2	1st Floor	38 /38	4 /5				0 /	0 /5	0 /				
3	2nd Floor	38 /38	4 /5				0 /	0 /5	0 /				
4	3rd Floor	38 /38	4 /5				0 /	0 /5	0 /	- 2 1 2			
	Total	155 /155	17 /20	/	/	/	0 /0	0 /20	0 /0	/	10000 Ltrs /50000 Ltrs. Ltrs	/	450 LPM /05 Nos. 450 LPM

• Provide ABC 5 kg/6 kg fire extinguishers

8. The Officers of the department have recommended to issue The No Objection Certificate for

M 23 09-11-2023, 19:03

Occupancy of Non MSB Educational Building (B1) belonging to KJR Educational Society Sy.No.342, D.No. 1-90-KC1, Chinna Tekur Village, Kallur Mandal, Kurnool District, subject to the following conditions.

The No Objection Certificate for Occupancy is issued subject to the following conditions:

- 1. This NOC is issued only in the Fire Safety Point of View and this doesnot give the Applicant a right to claim ownership of the property.
- 2. All fire safety systems provided shall be maintained in trim working condition at all times.
- 3. All Security/ Maintenance personnel shall be trained on the usage of fire equipment provided.
- 4. Fire Drills shall be conducted once in every 3 months.
- 5. As per report of Non MSB Inspection committee; the NOC Committee has scrutinized the Inspection Committee Report along with Proposals and recommended for issuance of No Objection Certificate for Occupancy subject to the following Conditions.

SI	As Builder	As Occupant	As Security Personnel		
	All the fire protection arrangements shall be	All the escape/exit routes	All the occupants must know		
1	maintained in good condition as seen during inspection.	shall not be kept locked/blocked or encroached	the correct method of operation of the fire fighting system installed.		
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilty of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.		
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.		
4	This No objection Certificate for occupancy is valid for one year from the date of issue of this letter	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once from nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.		

- 6. This No Objection Certificate for Occupancy is valid for a period of one year only from the date of issue of this letter. It is the responsibility of the builder to apply for Renewal of No Objection Certificate for Occupancy, duly remitting the User Charges as per G.O.Ms.No.71, Home (Prison-A) Department, dated 01-04-2010 and G.O.Ms.No.140, Home (Prison & Fire) Department, dated.04-09-2015, before expiry of this No Objection Certificate.
- 9. The following deficiencies are identified by the officers of the department and need to be attended to by the management.
 - This Occupancy NOC is issued from Fire Safety Point of view only

00g/1/23

F0 FF basing on recommendation of the inspection Committee and this Occupancy NOC is not for claiming proprietary or ownership rights. Further, in case of any deviation noticed with respect to this renewal NOC after issuance of this Occupancy NOC, the same Occupancy NOC shall be liable for cancellation at any time.

The Management has to maintain Fire Safety Measures and other installations in good working condition at all times and the Responsibility of Fire Fighting equipment maintenance lies with the management as seen & tested by the committee at the time of inspection.

In view of the above, as per the recommendations of the NOC Committee, the No Objection Certificate for Occupancy is hereby issued to the Newly constructed Non Multi Storeyed Building subject to the above conditions.

Your Sincerely,

Andhra Pradesh

Copy to KJR Educational Society, Delhi Public School run by KJR Educational Society,

Sy.No.342, D.No. 1-90-KC1, Chinna Tekur Village, Kallur Mandal, Kurnool District

Copy to Chief Office for Record Purpose

Copy to District Fire Officer concerned

Copy to Assistant District Fire Officer concerned

Copy to Station Fire Officer concerned